

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Influent Flow and Loading

### 1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.3556	x	181	x	8.34	=	538
February	0.3480	x	169	x	8.34	=	489
March	0.4359	x	117	x	8.34	=	425
April	0.3983	x	168	x	8.34	=	557
May	0.3647	x	180	x	8.34	=	547
June	0.3476	x	149	x	8.34	=	432
July	0.3368	x	139	x	8.34	=	391
August	0.3303	x	169	x	8.34	=	464
September	0.3145	x	180	x	8.34	=	472
October	0.3291	x	151	x	8.34	=	413
November	0.3203	x	162	x	8.34	=	433
December	0.3159	x	194	x	8.34	=	511

### 2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	1.4	x	90	=	1.26
		x	100	=	1.4
Design BOD, lbs/day	1450	x	90	=	1305
		x	100	=	1450

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
<b>Total Number of Points</b>					<b>0</b>

0

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 2021

## 3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?  
● Yes Enter last calibration date (MM/DD/YYYY)

2021-06-10

○ No

If No, please explain:

## 4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

● Yes

○ No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

○ Yes

● No

If Yes, please explain:

## 5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

○ Yes

○ Yes

○ Yes

● No

● No

● No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

○ Yes

gallons

● No

Holding Tanks

○ Yes

gallons

● No

Grease Traps

○ Yes

gallons

● No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

## 6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

● Yes

○ No

If yes, describe the situation and your community's response.

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

5/6/2022

**2021**

In the months of Jan and into Feb we experienced a slug load that gave us high effluent ammonia levels. We took action and grabbed another plants bugs and put them in our system. We were able to get things back to normal.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Effluent Quality and Plant Performance (BOD/CBOD)

### 1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	50	45	4	1	0	0
February	50	45	6	1	0	0
March	50	45	8	1	0	0
April	50	45	6	1	0	0
May	50	45	11	1	0	0
June	50	45	1	1	0	0
July	50	45	2	1	0	0
August	50	45	2	1	0	0
September	50	45	3	1	0	0
October	50	45	2	1	0	0
November	50	45	2	1	0	0
December	50	45	21	1	0	0

\* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
<b>Total number of points</b>			<b>0</b>

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

### 2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

Effluent flow is calculated from measuring elevation and referring to the calibration chart.

### 3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

High effluent ammonia

### 4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

<p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?</p> <p><input type="radio"/> Yes</p> <p><input type="radio"/> No</p> <p><input checked="" type="radio"/> N/A</p> <p>Please explain unless not applicable:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Effluent Quality and Plant Performance (Total Nitrogen)

### 1. Effluent Total Nitrogen Results

#### 1.1 Verify the following monthly average effluent values, exceedances, and points for Total N

Outfall No. 001	Monthly Average N Limit (mg/L)	Effluent Monthly Average N (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	10	8.686	1	0
February	10	9.301	1	0
March	10	8.847	1	0
April	10	8.985	1	0
May	10	6.98	1	0
June	10	6.198	1	0
July	10	5.921	1	0
August	10	6.268	1	0
September	10	8.171	1	0
October	10	9.926	1	0
November	10	9.405	1	0
December	10	8.898	1	0
Months of Discharge/yr			12	
<b>Points per each exceedance with 12 months of discharge:</b>				<b>10</b>
Exceedances				0
<b>Total Number of Points</b>				<b>0</b>

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

#### 1.2 If any violations occurred, what action was taken to regain compliance?

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 2021

## Groundwater Quality

### 1. Groundwater Quality Standards

1.1 At any time in the past year were there Preventative Action Limit (PAL) or Alternative Concentration Limit (ACL) exceedances of public health and welfare parameters in any groundwater monitoring wells downgradient of the discharge location?

- Yes
- No

If Yes, please list the exceedances in each downgradient well:

3-9-21-Well 112 Chloride 202 TDS-803 Well 114-TDS-587 114A-Chloride-197 TDS-867 Well 113-Chloride-259 TDS-933 Well 113A Chloride-183 TDS-810  
6-15-21-Well 114A-TDS-693 Well 112-Chloride-216 TDS-557 Well 113-Chloride-318 TDS-803 Well 113A-Chloride-260 TDS-680  
7-20-21-Well 112-Chloride-217 TDS-720 Well 113-Chloride-329 Nitrite+Nitrate-8.89 TDS-1207 Well 113A-Chloride-270 Nitrite+Nitrate-7.84 TDS-757 Well 114-Chloride-189 TDS-650 Well 114A-Chloride-18- TDS-610  
10-12-21-Well 112-Chloride-320 TDS-983 Well 113-Chloride-370 Nitrite+Nitrate-8.24 TDS-890 Well 113A-Chloride-350 TDS-973 Well 114-Chloride-240 TDS-1033 Well 114A-Chloride-270 TDS-880

1.2 At any time in the past year were there Enforcement Standard (ES) or ES Alternative Concentration Limit (ACL) exceedances in any groundwater monitoring well downgradient of the discharge location?

- Yes (20 points)
- No (If no, proceed to question 1.3)
- N/A - Based on a Department confirmation that the hydrogeologic situation is, in effect, a diffuse surface water discharge system.

If Yes, please list the exceedances in each well:

6-15-21-Well 113-318 Well 113A-260 Chloride  
7-20-21- Well 113-329 Well 113A-270 Chloride  
3-9-21-Well 113-259 Chloride  
10-12-21- Well 114A 270 Well 113-370 Well 113A 350 Chloride

1.3 At any time in the past year were there Enforcement Standard (ES) or ES Alternative Concentration Limit (ACL) exceedances at any point of standards application monitoring well? Point of standards application monitoring wells are those wells used to determine if an ES or ACL has been exceeded at any one or more of the following: 1) Any point of groundwater use; 2) Any point beyond the property boundary on which the facility is located; 3) Any point beyond the design management zone.

- Yes (10 points)
- No
- N/A - Based on a Department confirmation that the hydrogeologic situation is, in effect, a diffuse surface water discharge system rather than a discharge system potentially impacting the groundwater beyond a groundwater compliance boundary. In this case the facility may have received an NR 140.28 exemption.

If Yes, please list the exceedances in each well:

Well 112 Chloride 320 10-12-21

30

### 2. Groundwater Evaluation Report

2.1 Has a comprehensive Groundwater Compliance Evaluation Report been done by either your consultant or the Department ?

- Yes Date:

- No

If yes, what were the findings:

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

--	--

<b>Total Points Generated</b>	30
<b>Score (100 - Total Points Generated)</b>	70
<b>Section Grade</b>	<b>D</b>



# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Biosolids Quality and Management

### 1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

### 3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

#### Outfall No. 003 - Screw Press Sludge (Cake)

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75										1.4232				0	0
Cadmium		39	85										<3.754				0	0
Copper		1500	4300										1014				0	0
Lead		300	840										32				0	0
Mercury		17	57										.8				0	0
Molybdenum	60		75										7.2			0		0
Nickel	336		420										<11			0		0
Selenium	80		100										5.9			0		0
Zinc		2800	7500										662				0	0

#### Outfall No. 004 - Drying Bed Sludge (Cake)

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75										0				0	0
Cadmium		39	85										0				0	0
Copper		1500	4300										0				0	0
Lead		300	840										0				0	0
Mercury		17	57										0				0	0
Molybdenum	60		75										0			0		0
Nickel	336		420										0			0		0
Selenium	80		100										0			0		0
Zinc		2800	7500										0				0	0

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Outfall No. 002 - LAGOON SLUDGE (Liquid)

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75										0				0	0
Cadmium																	0	0
Copper		1500	4300										0				0	0
Lead		300	840										0				0	0
Mercury		17	57										0				0	0
Molybdenum	60		75										0			0		0
Nickel	336		420										0			0		0
Selenium	80		100										0			0		0
Zinc		2800	7500										0				0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)
- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?

## 6. Biosolids Storage

6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?

- >= 180 days (0 Points)
- 150 - 179 days (10 Points)
- 120 - 149 days (20 Points)
- 90 - 119 days (30 Points)
- < 90 days (40 Points)
- N/A (0 Points)

6.2 If you checked N/A above, explain why.

## 7. Issues

7.1 Describe any outstanding biosolids issues with treatment, use or overall management:

None

0

0

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><li>● Yes (Continue with question 2) <input type="checkbox"/><input type="checkbox"/></li><li>○ No (40 points) <input type="checkbox"/><input type="checkbox"/></li></ul> <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No (10 points)</li></ul> <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><li>● Yes<ul style="list-style-type: none"><li>○ Paper file system</li><li>○ Computer system</li><li>● Both paper and computer system</li></ul></li><li>○ No (10 points)</li></ul>	<b>0</b>
<p>3. O&amp;M Manual</p> <p>3.1 Does your plant have a detailed O&amp;M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul>	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><li>● Excellent</li><li>○ Very good</li><li>○ Good</li><li>○ Fair</li><li>○ Poor</li></ul> <p>Describe your rating:</p>	

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

We use JobCal for maintenance scheduling. We also perform a walk around inspection several times per day.

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Operator Certification and Education

### 1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

DALE R ROBERTS

Certification No:

36539

0

### 2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Basic	OIT	Basic	Advanced
A1	Suspended Growth Processes	X			X
A2	Attached Growth Processes				
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural				
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X			X
C	Biological Solids/Sludges	X			X
P	Total Phosphorus				
N	Total Nitrogen	X			X
D	Disinfection				
L	Laboratory				
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	NA	X

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- Yes (0 points)
- No (20 points)

### 3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff
- An arrangement with another certified operator
- An arrangement with another community with a certified operator
- An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year
- A consultant to serve as your certified operator
- None of the above (20 points)

If "None of the above" is selected, please explain:

0

### 4. Continuing Education Credits

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

OIT and Basic Certification: ○ Averaging 6 or more CECs per year. ○ Averaging less than 6 CECs per year. Advanced Certification: ● Averaging 8 or more CECs per year. ○ Averaging less than 8 CECs per year.	
---	--

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Financial Management

1. Provider of Financial Information Name: <input type="text" value="Julie Roberts"/> Telephone: <input type="text" value="608-882-2266"/> (XXX) XXX-XXXX E-Mail Address (optional): <input type="text" value="julie.roberts@ci.evansville.wi.gov"/>		
2. Treatment Works Operating Revenues 2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ? ● Yes (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ No (40 points) If No, please explain: <input type="text"/> 2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised? Year: <input type="text" value="2021"/> ● 0-2 years ago (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ 3 or more years ago (20 points) <input type="checkbox"/> <input type="checkbox"/> ○ N/A (private facility) 2.3 Did you have a special account (e.g., CFWP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system? ● Yes (0 points) ○ No (40 points)		<b>0</b>
REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]		
3. Equipment Replacement Funds 3.1 When was the Equipment Replacement Fund last reviewed and/or revised? Year: <input type="text" value="2021"/> ● 1-2 years ago (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ 3 or more years ago (20 points) <input type="checkbox"/> <input type="checkbox"/> ○ N/A If N/A, please explain: <input type="text"/>		
3.2 Equipment Replacement Fund Activity		
<b>3.2.1 Ending Balance Reported on Last Year's CMAR</b>	\$ <input type="text" value="898,976.23"/>	
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	+ \$ <input type="text" value="1.00"/>	
3.2.3 Adjusted January 1st Beginning Balance	\$ <input type="text" value="898,977.23"/>	
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+ \$ <input type="text" value="44,219.22"/>	



# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below\*)

- \$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 943,196.45

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund? \$ 504,722.00

0

Please note: If you had a CWF loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

## 4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	10 Year Capital Plan - Sewer Main replacement and lining from 2021 to 2030.	5381831	2028
2	6 Remaining Lift Station Rebuild/Repairs 2021-2030	1740000	2028

## 5. Financial Management General Comments

### ENERGY EFFICIENCY AND USE

## 6. Collection System

### 6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

#### **COLLECTION SYSTEM PUMPAGE: Total Power Consumed**

Number of Municipally Owned Pump/Lift Stations:

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	12,288	6
February	12,576	6
March	12,672	5
April	9,888	6
May	7,776	6
June	6,336	5
July	6,240	5
August	6,144	6
September	5,568	5
October	6,720	5
November	7,488	5
December	8,448	5
<b>Total</b>	<b>102,144</b>	<b>65</b>
<b>Average</b>	<b>8,512</b>	<b>5</b>

## 6.1.2 Comments:

## 6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

## 6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

No

Yes

Year:

By Whom:

Describe and Comment:

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## 6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

None

## 7. Treatment Facility

### 7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

#### TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	39,744	11.02	3,607	16.68	2,383	1,189
February	38,016	9.74	3,903	13.69	2,777	1,501
March	36,864	13.51	2,729	13.18	2,797	802
April	36,576	11.95	3,061	16.71	2,189	364
May	38,880	11.31	3,438	16.96	2,292	183
June	38,880	10.43	3,728	12.96	3,000	28
July	40,320	10.44	3,862	12.12	3,327	6
August	40,032	10.24	3,909	14.38	2,784	6
September	38,016	9.44	4,027	14.16	2,685	6
October	39,456	10.20	3,868	12.80	3,083	8
November	36,000	9.61	3,746	12.99	2,771	437
December	38,880	9.79	3,971	15.84	2,455	841
<b>Total</b>	<b>461,664</b>	<b>127.68</b>		<b>172.47</b>		<b>5,371</b>
<b>Average</b>	<b>38,472</b>	<b>10.64</b>	<b>3,654</b>	<b>14.37</b>	<b>2,712</b>	<b>448</b>

7.1.2 Comments:

### 7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 2021

## 7.2.2 Comments:

## 7.3 Future Energy Related Equipment

### 7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

Electric UTV for the plant

## 8. Biogas Generation

### 8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

## 9. Energy Efficiency Study

### 9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

2009

By Whom:

Foth Engineering

Describe and Comment:

Plant reconstruction and the installation of a wind turbine

Part of the facility

Year:

By Whom:

Describe and Comment:

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

5/6/2022

2021

## Sanitary Sewer Collection Systems

### 1. Capacity, Management, Operation, and Maintenance (CMOM) Program

#### 1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

#### 1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

#### 1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Did you accomplish them?

- Yes
- No

If No, explain:

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Sewer use ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY)

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance

- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

A description of routine operation and maintenance activities (see question 2 below)  
 Capacity assessment program  
 Basement back assessment and correction  
 Regular O&M training  
 Design and Performance Provisions [NR 210.23 (4) (e)]    
 What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?  
 State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements  
 Construction, Inspection, and Testing  
 Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]    
 Does your emergency response capability include:  
 Responsible personnel communication procedures  
 Response order, timing and clean-up  
 Public notification protocols  
 Training  
 Emergency operation protocols and implementation procedures  
 Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]    
 Special Studies Last Year (check only those that apply):  
 Infiltration/Inflow (I/I) Analysis  
 Sewer System Evaluation Survey (SSES)  
 Sewer Evaluation and Capacity Management Plan (SECAP)  
 Lift Station Evaluation Report  
 Others:

0

## 2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="25"/>	% of system/year
Root removal	<input type="text" value="25"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="25"/>	% of system/year
Manhole inspections	<input type="text" value="25"/>	% of system/year
Lift station O&M	<input type="text" value="8"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="0"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input type="text" value="0"/>	% of private services

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

River or water crossings  % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

### 3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="22.4"/>	Total actual amount of precipitation last year in inches
<input type="text" value="36"/>	Annual average precipitation (for your location)
<input type="text" value="28.4"/>	Miles of sanitary sewer
<input type="text" value="8"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="0"/>	Number of basement backup occurrences
<input type="text" value="0"/>	Number of complaints
<input type="text" value="0.345"/>	Average daily flow in MGD (if available)
<input type="text" value="0.436"/>	Peak monthly flow in MGD (if available)
<input type="text" value="0.74"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.00"/>	Basement backups (number/sewer mile)
<input type="text" value="0.00"/>	Complaints (number/sewer mile)
<input type="text" value="1.3"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text" value="2.1"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

### 4. Overflows

#### LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED \*\*

Date	Location	Cause	Estimated Volume
None reported			

\*\* If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

### 5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

- Yes
- No

If Yes, please describe:



# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

<div data-bbox="133 205 1461 260" style="border: 1px solid black; height: 26px;"></div> <p>5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:</p> <div data-bbox="126 302 1461 352" style="border: 1px solid black; padding: 2px;">None</div> <p>5.4 What is being done to address infiltration/inflow in your collection system?</p> <div data-bbox="126 407 1461 478" style="border: 1px solid black; padding: 2px;">We are still in the process of doing our I/I study. We televise any known problem areas and have a budget for lining these areas.</div>
--

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 **2021**

## Grading Summary

WPDES No: 0023957

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
Nitrogen	A	4	7	28
Groundwater	D	1	7	7
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
<b>TOTALS</b>			<b>38</b>	<b>131</b>
<b>GRADE POINT AVERAGE (GPA) = 3.45</b>				

### Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

# Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:  
5/6/2022 2021

## Resolution or Owner's Statement

Name of Governing  
Body or Owner:

City of Evansville

Date of Resolution or  
Action Taken:

Resolution Number:

Date of Submittal:

### ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: Nitrogen: Grade = A

Groundwater: Grade = D

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

### ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

**G.P.A. = 3.45**