

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.4272	x	255	x	8.34	=	909
February	0.4233	x	243	x	8.34	=	856
March	0.4247	x	214	x	8.34	=	758
April	0.5064	x	197	x	8.34	=	833
May	0.5224	x	145	x	8.34	=	630
June	0.4770	x	125	x	8.34	=	498
July	0.7080	x	123	x	8.34	=	728
August	0.5528	x	107	x	8.34	=	493
September	0.4443	x	168	x	8.34	=	621
October	0.4330	x	159	x	8.34	=	574
November	0.3896	x	193	x	8.34	=	626
December	0.3668	x	176	x	8.34	=	539

2. Maximum Monthly Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	1.4	x	90	=	1.26
		x	100	=	1.4
Design (C)BOD, lbs/day	1450	x	90	=	1305
		x	100	=	1450

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

Yes

Enter last calibration date (MM/DD/YYYY)

2017-07-28

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018
2017

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	50	45	8	1	0	0
February	50	45	15	1	0	0
March	50	45	16	1	0	0
April	50	45	12	1	0	0
May	50	45	9	1	0	0
June	50	45	5	1	0	0
July	50	45	3	1	0	0
August	50	45	2	1	0	0
September	50	45	2	1	0	0
October	50	45	3	1	0	0
November	50	45	3	1	0	0
December	50	45	3	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12	
Points per each exceedance with 12 months of discharge	7	3
Exceedances	0	0
Points	0	0
Total number of points		0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is 12/6 = 2.0

1.2 If any violations occurred, what action was taken to regain compliance?

[Redacted]

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes

Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

Effluent flow is calculated from measuring elevation and referring to the calibration chart.

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

None

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

If Yes, please explain:

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

- Yes
- No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

- Yes
- No
- N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

Groundwater Quality

1. Groundwater Quality Standards

1.1 At any time in the past year were there Preventative Action Limit (PAL) or Alternative Concentration Limit (ACL) exceedances of public health and welfare parameters in any groundwater monitoring wells downgradient of the discharge location?

- Yes
- No

If Yes, please list the exceedances in each downgradient well:

The Chloride and TDS was over the PALs in the downgradient monitoring wells.

1.2 At any time in the past year were there Enforcement Standard (ES) or ES Alternative Concentration Limit (ACL) exceedances in any groundwater monitoring well downgradient of the discharge location?

- Yes (20 points)
- No (If no, proceed to question 1.3)
- N/A - Based on a Department confirmation that the hydrogeologic situation is, in effect, a diffuse surface water discharge system.

If Yes, please list the exceedances in each well:

The Chloride was over the ES on 12-5-17 in well 114A (255) and well 113A (256).

1.3 At any time in the past year were there Enforcement Standard (ES) or ES Alternative Concentration Limit (ACL) exceedances at any point of standards application monitoring well? Point of standards application monitoring wells are those wells used to determine if an ES or ACL has been exceeded at any one or more of the following: 1) Any point of groundwater use; 2) Any point beyond the property boundary on which the facility is located; 3) Any point beyond the design management zone.

- Yes (10 points)
- No
- N/A - Based on a Department confirmation that the hydrogeologic situation is, in effect, a diffuse surface water discharge system rather than a discharge system potentially impacting the groundwater beyond a groundwater compliance boundary. In this case the facility may have received an NR 140.28 exemption.

If Yes, please list the exceedances in each well:

[Redacted]

2. Groundwater Evaluation Report

2.1 Has a comprehensive Groundwater Compliance Evaluation Report been done by either your consultant or the Department ?

- Yes Date: [Redacted]
- No

If yes, what were the findings:

[Redacted]

Total Points Generated	20
Score (100 - Total Points Generated)	80
Section Grade	C

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

2. Land Application Site

2.1 Last Year's Approved and Active Land Application Sites

2.1.1 How many acres did you have?

483 acres

2.1.2 How many acres did you use?

18 acres

2.2 If you did not have enough acres for your land application needs, what action was taken?

2.3 Did you overapply nitrogen on any of your approved land application sites you used last year?

Yes (30 points)

No

2.4 Have all the sites you used last year for land application been soil tested in the previous 4 years?

Yes

No (10 points)

N/A

0

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 004 - SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75			3										0	0	
Cadmium		39	85			.73										0	0	
Copper		1500	4300			680										0	0	
Lead		300	840			15										0	0	
Mercury		17	57			.39										0	0	
Molybdenum	60		75			3.8										0	0	
Nickel	336		420			11										0	0	
Selenium	80		100			7.2										0	0	
Zinc		2800	7500			480										0	0	

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

0 (0 Points)

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)

- N/A - Did not exceed limits or no HQ limit applies (0 points)

- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

0

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken?

Has the source of the metals been identified?

4. Pathogen Control (per outfall):

4.1 Verify the following information. If any information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Outfall Number:	004
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	01/01/2017 - 12/31/2017
Density:	3,800
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	
Process Description:	

0

4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.

4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?

- Yes (40 Points)
- No

If yes, what action was taken?

5. Vector Attraction Reduction (per outfall):

5.1 Verify the following information. If any of the information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018
2017

Outfall Number:	004	0
Method Date:	12/31/2017	
Option Used To Satisfy Requirement:	Incorporation when land apply	
Requirement Met:	Yes	
Land Applied:	Yes	
Limit (if applicable):		
Results (if applicable):		

5.2 Was the limit exceeded or the process criteria not met at the time of land application?

Yes (40 Points)

No

If yes, what action was taken?

6. Biosolids Storage

6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?

>= 180 days (0 Points)

150 - 179 days (10 Points)

120 - 149 days (20 Points)

90 - 119 days (30 Points)

< 90 days (40 Points)

N/A (0 Points)

6.2 If you checked N/A above, explain why.

10

7. Issues

7.1 Describe any outstanding biosolids issues with treatment, use or overall management:

capacity is being fixed with the 2018-2019 project.

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

Staffing and Preventative Maintenance (All Treatment Plants)

1. Plant Staffing

1.1 Was your wastewater treatment plant adequately staffed last year?

- Yes
- No

If No, please explain:

Could use more help/staff for:

1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?

- Yes
- No

If No, please explain:

2. Preventative Maintenance

2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?

- Yes (Continue with question 2)
- No (40 points)

If No, please explain, then go to question 3:

2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?

- Yes
- No (10 points)

2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?

- Yes
 - Paper file system
 - Computer system
 - Both paper and computer system
 - No (10 points)

3. O&M Manual

3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?

- Yes
- No

4. Overall Maintenance /Repairs

4.1 Rate the overall maintenance of your wastewater plant.

- Excellent
- Very good
- Good
- Fair
- Poor

Describe your rating:

0

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

I use Job cal for the maintenance scheduling. All the bearings are greased and the oil is changed when it is due. A walk around is performed multiple times every day to make sure everything is running smooth.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

Operator Certification and Education

1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

DALE R ROBERTS

0

Certification No:

36539

0

2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Basic	OIT	Basic	Advanced
A1	Suspended Growth Processes	X			X
A2	Attached Growth Processes				
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural				
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X			X
C	Biological Solids/Sludges	X			X
P	Total Phosphorus				
N	Total Nitrogen	X	NA	NA	NA
D	Disinfection				
L	Laboratory				
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	NA	NA

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS, N and A5 not required in 2016; subclass SS is basic level only.)

- Yes (0 points)
- No (20 points)

3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff
- An arrangement with another certified operator
- An arrangement with another community with a certified operator
- An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year
- A consultant to serve as your certified operator
- None of the above (20 points)

If "None of the above" is selected, please explain:

0

4. Continuing Education Credits

0

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

OIT and Basic Certification:

- Averaging 6 or more CECs per year.
- Averaging less than 6 CECs per year.

Advanced Certification:

- Averaging 8 or more CECs per year.
- Averaging less than 8 CECs per year.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

Financial Management

1. Provider of Financial Information

Name:

Ian Rigg

Telephone:

608-882-2263

(XXX) XXX-XXXX

E-Mail Address
(optional):

ian.rigg@ci.evansville.wi.gov

2. Treatment Works Operating Revenues

2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?

- Yes (0 points)
- No (40 points)

If No, please explain:

[Redacted]

2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?

Year:

2018

0

- 0-2 years ago (0 points)
- 3 or more years ago (20 points)
- N/A (private facility)

2.3 Did you have a special account (e.g., CWFP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?

- Yes (0 points)
- No (40 points)

REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]

3. Equipment Replacement Funds

3.1 When was the Equipment Replacement Fund last reviewed and/or revised?

Year:

2018

- 1-2 years ago (0 points)
- 3 or more years ago (20 points)
- N/A

If N/A, please explain:

[Redacted]

3.2 Equipment Replacement Fund Activity

3.2.1 Ending Balance Reported on Last Year's CMAR

\$ 682,499.00

3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)

\$ 43,170.00

3.2.3 Adjusted January 1st Beginning Balance

\$ 725,669.00

3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)

+ \$ 0.00

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box
3.2.6.1 below*)

- \$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 725,669.00

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund? \$ 304,571.00

0

Please note: If you had a CWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	10 YEAR CIP ANNUAL REVIEW - Sewer Main replacement 2018-2028	1,606,000	2028
2	WWTP - Screw Press De-watering addition and WWTP upgrades	2,700,000	2018
3	Main Lift Station rebuild - 2018	1,000,000	2018
4	6 Remaining Lift Station Rebuild/Repairs 2019-2028	1,180,000	2028

5. Financial Management General Comments

[Form Field]

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations: [Form Field] 8

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018
2017

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	8,819	4
February	12,047	3
March	11,062	3
April	9,648	3
May	9,892	3
June	9,270	3
July	10,679	4
August	10,822	3
September	10,080	3
October	7,222	2
November	10,025	3
December	11,395	3
Total	120,961	37
Average	10,080	3

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Commination or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

- No
- Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018
2017

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	41,760	13.24	3,154	28.18	1,482	1,187
February	40,032	11.85	3,378	23.97	1,670	851
March	48,096	13.17	3,652	23.50	2,047	835
April	40,896	15.19	2,692	24.99	1,636	374
May	43,776	16.19	2,704	19.53	2,241	246
June	48,096	14.31	3,361	14.94	3,219	47
July	39,744	21.95	1,811	22.57	1,761	6
August	36,000	17.14	2,100	15.28	2,356	4
September	39,456	13.33	2,960	18.63	2,118	6
October	31,968	13.42	2,382	17.79	1,797	4
November	36,864	11.69	3,153	18.78	1,963	89
December	35,424	11.37	3,116	16.71	2,120	195
Total	482,112	172.85		244.87		3,844
Average	40,176	14.40	2,872	20.41	2,034	320

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

7.2.2 Comments:

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

We are putting in new blowers for the VLR and for the digester that are more efficient.
2018-2019

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

- No
- Yes

If Yes, how is the biogas used (Check all that apply):

- Flared Off
- Building Heat
- Process Heat
- Generate Electricity
- Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

- No
- Yes
- Entire facility

Year:

2009

By Whom:

Foth Engineering

Describe and Comment:

Part of the 2009 plant reconstruction and addition of the wind turbine.

- Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

● Yes

○ No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

● Yes

○ No (30 points)

○ N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Clean 25% of the collection system and televise areas with suspected problems.

Did you accomplish them?

● Yes

○ No

If No, explain:

Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

Organizational structure and positions (eg. organizational chart and position descriptions)

Internal and external lines of communication responsibilities

Person(s) responsible for reporting overflow events to the department and the public

Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Sewer use ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY)

Does your sewer use ordinance or other legally binding document address the following:

Private property inflow and infiltration

New sewer and building sewer design, construction, installation, testing and inspection

Rehabilitated sewer and lift station installation, testing and inspection

Sewage flows satellite system and large private users are monitored and controlled, as necessary

Fat, oil and grease control

Enforcement procedures for sewer use non-compliance

Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

Equipment and replacement part inventories

Up-to-date sewer system map

A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:
6/21/2018 **2017**

- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training
- Design and Performance Provisions [NR 210.23 (4) (e)]

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

0

- Overflow Emergency Response Plan [NR 210.23 (4) (f)]

Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures

- Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]

- Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning % of system/year

Root removal % of system/year

Flow monitoring % of system/year

Smoke testing % of system/year

Sewer line televising % of system/year

Manhole inspections % of system/year

Lift station O&M # per L.S./year

Manhole rehabilitation % of manholes rehabbed

Mainline rehabilitation % of sewer lines rehabbed

Private sewer inspections % of system/year

Private sewer I/I removal % of private services

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

River or water crossings

0 % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

38.28	Total actual amount of precipitation last year in inches
35.2	Annual average precipitation (for your location)
27	Miles of sanitary sewer
8	Number of lift stations
0	Number of lift station failures
0	Number of sewer pipe failures
0	Number of basement backup occurrences
0	Number of complaints
0.4729	Average daily flow in MGD (if available)
0.708	Peak monthly flow in MGD (if available)
2.225	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

0.00	Lift station failures (failures/year)
0.00	Sewer pipe failures (pipe failures/sewer mile/yr)
0.00	Sanitary sewer overflows (number/sewer mile/yr)
0.00	Basement backups (number/sewer mile)
0.00	Complaints (number/sewer mile)
1.5	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
4.7	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

	Date	Location	Cause	Estimated Volume (MG)
None reported				

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

After it rains any amount there is a noticeable amount of clear water coming through the system.

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

- Yes
- No

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

None

5.4 What is being done to address infiltration/inflow in your collection system?

Replacement of the collection system as we replace roads.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

Grading Summary

WPDES No: 0023957

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
Groundwater	C	2	7	14
Biosolids	B	3	5	15
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS		31		105
GRADE POINT AVERAGE (GPA) = 3.39				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)

Compliance Maintenance Annual Report

Evansville Wastewater Treatment Facility

Last Updated: Reporting For:

6/21/2018

2017

Resolution or Owner's Statement

Name of Governing Body or Owner:

City of Evansville-City Council

Date of Resolution or Action Taken:

2018-06-12

Resolution Number:

2018-16

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

[Redacted]

Effluent Quality: BOD: Grade = A

[Redacted]

Groundwater: Grade = C

We are working on reducing the amount of road salt we are using on the roads by putting a brine system on one of the trucks to try to reduce the amount of chloride coming into the sewer system.

Biosolids Quality and Management: Grade = B

[Redacted]

Staffing: Grade = A

[Redacted]

Operator Certification: Grade = A

[Redacted]

Financial Management: Grade = A

[Redacted]

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

[Redacted]

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.39

[Redacted]